



Parish President Larry Cochran



ST. CHARLES PARISH  
**WATER QUALITY REPORT 2017**



Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The employees of the St. Charles Parish Water Department work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life and our children's future.

Parish President Larry Cochran is pleased to report that our drinking water is safe and meets Federal and State requirements. In order to ensure that tap water is safe to drink, The Environmental Protection Agency prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. If you have any questions about this report or your water utility, please contact Robert Brou or Dustin Zeringue at (985) 783-5110. We want our valued customers to be informed about their water.

The Louisiana Department of Health & Hospitals/Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The table on the second page shows the results of our monitoring for the period of January 1 to December 31, 2017. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

St. Charles Parish vigilantly safeguards the quality of its water. Our employees live in the same neighborhoods you do. When we turn on our taps we expect what you expect a reliable source of high-quality drinking water.

This report is a summary of the quality of water provided to our customers for the last year. It is a record reflecting the hard work of our employees to bring you water that is absolutely safe. Included are details about where your water comes from, what it contains and how it compares to standards set by regulatory agencies. The St. Charles Parish Department of Waterworks is committed to providing you with information about your water supply, because customers who are well-informed are our best allies in supporting improvements necessary to maintain the highest drinking water standards.

If present, elevated levels of lead cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. St. Charles Water Dist No 2 Wb is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

We are pleased to present to you this year's Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

SOURCE NAME	SOURCE WATER TYPE	SOURCE WATER BODY NAME
SURFACE WATER INTAKE	Surface Water	MISSISSIPPI RIVER

The sources of drinking water (both tap water and bottled water) include rivers, lakes streams, ponds, reservoirs, springs and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

**Microbial Contaminants** - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic Contaminants** - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and Herbicides** - which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

**Organic Chemical Contaminants** - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

**Radioactive Contaminants** - which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan (SWAP), our water system had a susceptibility rating of 'HIGH'. If you would like to review the (SWAP), please feel free to contact our office.

# West Bank Treated Water Quality Roundup - LA1089002

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2016. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

COMPLIANCE PERIOD		ANALYTE					TYPE
No Violations Occurred in the Calendar Year of 2017							
DISINFECTANT	DATE	HIGHEST RAA	UNIT	RANGE	MRDL	MRLDG	TYPICAL SOURCE
	2017	3.38	ppm	2.9 - 3.4	4	4	Water additive used to control microbes

*In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.*

REGULATED CONTAMINANTS	COLLECTION DATE	HIGHEST VALUE	RANGE	UNIT	MCL	MCLG	TYPICAL SOURCE
ARSENIC	1/25/2017	1.3	1.3	ppb	10	0	Erosion of natural deposits; Runoff from orchards; runoff from glass and electronic production wastes
BARIUM	1/25/2017	0.059	0.059	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	1/25/2017	0.74	0.74	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	1/25/2017	1.8	1.8	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; erosion of natural deposits
SELENIUM	1/25/2017	0.72	0.72	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; Discharge from mines

RADIONUCLIDES	COLLECTION DATE	HIGHEST VALUE	RANGE	UNIT	MCL	MCLG	TYPICAL SOURCE
COMBINED RADIUM (-226 & -228)	1/25/2017	1.13	1.13	pCi/l	5	0	Erosion of natural deposits
COMBINED URANIUM	1/25/2017	1.1	1.1	ug/l	30	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	1/25/2017	2.34	2.34	pCi/l	50	0	Decay of natural and man-made deposits. Note: The gross beta particle activity MCL is 4 millirems/year annual dose equivalent to the total body or any internal organ. 50 pCi/L is used as a screening level.

LEAD AND COPPER	DATE	90TH PERCENTILE	RANGE	UNIT	AL	SITES OVER AL	TYPICAL SOURCE
COPPER, FREE	2014 - 2016	0.4	0.1 - 0.6	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2014 - 2016	2	1 - 7	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

DISINFECTION BYPRODUCTS	SAMPLE POINT	PERIOD	HIGHEST LRAA	RANGE	UNIT	MCL	MCLG	TYPICAL SOURCE
TOTAL HALOACETIC ACIDS (HAA5)	ANNA ST @ T&P BRIDGE	2017	42	24.4 - 62.3	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	BAYOU GAUCHE	2017	38	21.1 - 51.2	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	DES ALLEMANDS SCHOOL	2017	42	23.4 - 54.4	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	HAHN STREET	2017	40	23.2 - 52.1	ppb	60	0	By-product of drinking water disinfection
TTHM	ANNA ST @ T&P BRIDGE	2017	68	43 - 96.4	ppb	80	0	By-product of drinking water chlorination
TTHM	BAYOU GAUCHE	2017	69	49.4 - 92	ppb	80	0	By-product of drinking water chlorination
TTHM	DES ALLEMANDS SCHOOL	2017	69	48.5 - 93.6	ppb	80	0	By-product of drinking water chlorination
TTHM	HAHN STREET	2017	63	45.4 - 79.5	ppb	80	0	By-product of drinking water chlorination



# West Bank Treated Water Quality Roundup - LA1089002 ~ Continued

SECONDARY CONTAMINANTS	COLLECTION DATE	YOUR HIGHEST VALUE	RANGE	UNIT	SMCL
ALUMINUM	4/6/2015	0.021	0.021	MG/L	0.05
CHLORIDE	3/1/2016	22.8	22.8	MG/L	250
PH	3/1/2016	7.3	7.3	SU	8.5
SULFATE	3/1/2016	36.2	36.2	MG/L	250
ZINC	1/25/2017	0.026	0.026	MG/L	5

REGULATED CONTAMINANTS	COLLECTION DATE	LOWEST MONTHLY % MEETING LIMIT	RANGE	MCL	UNIT	TYPICAL SOURCE
TURBIDITY	NA	100%	100%	0.3	NTU	Soil Runoff

  

REGULATED CONTAMINANTS	COLLECTION DATE	HIGHEST VALUE	RANGE	MCL	UNIT	TYPICAL SOURCE
TURBIDITY	4/8/16	0.17	.08 - .17	0.3	NTU	Soil Runoff

  

REGULATED CONTAMINANTS	COLLECTION DATE	HIGHEST VALUE	RANGE	MRDL	UNIT	TYPICAL SOURCE
DISINFECTANT	2017	3.38	2.9 - 3.4	4	PPM	

*Note: Turbidity is the measure of cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Its major sources include soil runoff. Turbidity has no health effects.*

**LISTED ABOVE** are contaminants detected in St. Charles Parish drinking water. All are below allowed levels. Not listed are the hundreds of other contaminants for which we tested that were not detected.

**IN THE TABLES ABOVE, YOU WILL FIND MANY TERMS AND ABBREVIATIONS YOU MIGHT NOT BE FAMILIAR WITH. TO HELP YOU BETTER UNDERSTAND THESE TERMS, WE'VE PROVIDED THE FOLLOWING DEFINITIONS BELOW.**

## \* DEFINITIONS

**PARTS PER MILLION (PPM) OR MILLIGRAMS PER LITER (MG/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

**PARTS PER BILLION (PPB) OR MICROGRAMS PER LITER (UG/L)** - One part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

**PIECOCURIES PER LITER (PC/L)** - Picocuries per liter is a measure of the radioactivity in water.

**NEPHELOMETRIC TURBIDITY UNIT (NTU)** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**ACTION LEVEL (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**BD** - Below Detection

**MAXIMUM CONTAMINANT LEVEL (MCL)** - The "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology.

**MAXIMUM CONTAMINANT LEVEL GOAL (MCLG)** - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.

**MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**CRYPTOSPORIDIUM DATA:** St. Charles Parish Water System conducted monthly source water monitoring for Cryptosporidium (Crypto) from January 2017 to December 2017. Crypto was not detected.

**SPECIAL INFO AVAILABLE** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly persons and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**CUSTOMER VIEWS WELCOME:** If you are interested in learning more about the water department and water quality, call our Customer Service office at (985) 783-5110. Contact Dustin Zeringue for individual or group guided water treatment plant tours. School groups are welcomed. The St. Charles Parish Council meets at 6:00 p.m. on the first and third Monday of each month at the Parish Courthouse in Hahnville. All sessions are open to the public.